

ALLEN COUNTY DRAINAGE BOARD

AGENDA

for Regular Meeting and/or Public Hearing at 9:30 am on: **4/27/2017**

Meeting held at CitizensSquare-Suite 035, 200 E. Berry Street, Fort Wayne, IN 46802-2737

Call to Order

Approval of Minutes from 4/13/17

Approval of Petitions

OBSTRUCTION/Motion to Proceed

Doc #: **17-124**
Project: Obstruction/N. County Line Rd E Subd Sec:
Drain Name: Drain #:
Action: Petition to Remove Obstruction in Mutual Drain or Natural Surface Water Course. Motion to proceed.
Surveyor Recommendation: **Surveyor recommends a motion to proceed to a public hearing on June 8, 2017.**

ENCROACHMENT

Doc #: **17-115**
Project: Private Residence/15120 E Lincoln Hwy Subd Sec:
Drain Name: Ryan No.2 Drain #: 14-15-084
Action: Petition for Encroachment within the drainage easement of Ryan No.2 Drain for new 3-car garage that will attach to existing house on E Lincoln Hwy in New Haven.
Surveyor Recommendation: **Surveyor recommends approval subject to proposed attached garage cannot be located closer to ditch than existing house.**

ENCROACHMENT

Doc #: **17-126**
Project: Fellowship of Evangelical Churches Subd Sec:
Drain Name: Salgy Drain #: 08-09-310
Action: Petition for Encroachment within the drainage easement of Salgy Drain for a dry detention basin and outlet pipe for Fellowship Church on Maplecrest Road.
Surveyor Recommendation: **Surveyor recommends approval.**

ENCROACHMENT

Doc #: **17-128**
Project: Private residence/13500 Parent Rd Subd Sec:
Drain Name: Meier Drain #: 09-29-900
Action: Petition for Encroachment within the drainage easement of Meier Drain for the existing 54" culvert used for access to north part of his property on Parent Road.
Surveyor Recommendation: **Surveyor recommends approval.**

ENCROACHMENT

Doc #: **17-122**
Project: ACHD/Bridge replacement Subd Sec:
Drain Name: Hamm Interceptor Drain #: 10-02-710
Action: Petition for Encroachment within the drainage easement of Hamm Interceptor Drain for replacement of bridge on River Road in Woodburn.
Surveyor Recommendation: **Surveyor recommends approval.**

ENCROACHMENT

Doc #: **17-129**
Project: Eagle Creek Subd Sec:
Drain Name: Eagle Creek Drain #: 11-28-042
Action: Petition for Encroachment within the drainage easement of Eagle Creek Drain for a new outflow to the pond to the west to allow better back yard drainage.
Surveyor Recommendation: **Surveyor recommends approval.**

ENCROACHMENT

Doc #: 17-130
Project: Walnut Hills Apartments Subd Sec:
Drain Name: Maria Flaugh Ditch Drain #: 11-13-850
Action: Petition for Encroachment within the drainage easement of Maria Flaugh Drain for a new culvert crossing on Getz Road for Walnut Hills Apartments.

Surveyor Recommendation: **Surveyor recommends approval subject to applicant obtaining IDNR consent for existing and future crossing culverts because installation is within Floodway limits.**

ENCROACHMENT

Doc #: 17-131
Project: City of Fort Wayne/Sanitary Sewer Subd Sec:
Drain Name: Mowrer Drain #: 08-24-068
Action: Petition for Encroachment within the drainage easement of Mowrer Drain for extension of City of Fort Wayne Sanitary Sewer Force Main crossing the drain via horizontal directional drilling at St. Joe Center and Wheelock Road.

Surveyor Recommendation: **Surveyor recommends approval subject to revising stream crossing cover depth from 3 feet to 5 feet for force main installation.**

ENCROACHMENT

Doc #: 17-132
Project: City of New Haven/culvert replacement Subd Sec:
Drain Name: Kamp Drain #: 13-13-811
Action: Petition for Encroachment within the drainage easement of Kamp Drain for a culvert replacement/repair by City of New Haven on Norland Lane and Greenmoor Drive.

Surveyor Recommendation: **Surveyor recommends approval. Proposed culverts are equal to existing size of culvert.**

ENCROACHMENT

Doc #: 17-133
Project: Indiana Fiber Optic Subd Sec:
Drain Name: Rinehold Drain #: 02-13-770
Action: Petition for Encroachment within the drainage easement of Rinehold Drain for installation of Fiber Optic cable boring a minimum of 5' under the drain on Vandolah Road.

Surveyor Recommendation: **Surveyor recommends approval.**

ENCROACHMENT

Doc #: 17-134
Project: Indiana Fiber Optic Subd Sec:
Drain Name: Warner, N. L Drain #: 02-13-820
Action: Petition for Encroachment within the drainage easement of NL Warner Drain for installation of Fiber Optic cable boring a minimum of 5' under the drain on Vandolah Road.

Surveyor Recommendation: **Surveyor recommends approval.**

ENCROACHMENT

Doc #: 17-135
Project: City of Fort Wayne/Sewer Repair Subd Sec:
Drain Name: Salgy Drain #: 08-09-310
Action: Petition for Encroachment within the drainage easement of the Salgy Drain for City Utilities Sewer Repair Project including a pipe installed 3.5' below the ditch bed off Rothman Road.

Surveyor Recommendation: **Surveyor recommends approval for gravity 8" Sanitary Sewer**

ENCROACHMENT

Doc #: 17-139
Project: City of Fort Wayne/Storm Sewer Subd Sec:
Drain Name: Virts Drain #: 13-32-180
Action: Petition for Encroachment within the drainage easement of the Virts Drain for City of Fort Wayne installation of new 15" storm sewer crossing Hessen Cassel and outfalling on east side of Hessen Cassel into the drain to improve drainage within the neighborhood. The 15" pipe will be replacing existing 12" RCP.

Surveyor Recommendation: **Surveyor recommends approval.**

Discussion . . .

Doc #: 17-125

Project: Watervale

Subd Sec:

Drain Name: McComb Br.2

Drain #: 02-21-200

Action: Discussion concerning designation of the McComb Br.2 tile location on the east side of Coldwater Road.

Surveyor Recommendation: Discussion regarding legal question. Can ACSO change our drainage maps moving McComb Br.2 Tile from west to east side of Coldwater Road without notification to landowners affected within the 150' R/W?

OTHER BUSINESS...

Next Public Hearing and Meeting: May 11, 2017 at 9:30 am, Room 035 CSQ

Next Regular Meeting: May 25, 2017 at 9:30 am, Room 035 CSQ

Allen County does not discriminate because of disability in the admission to, treatment or employment in, its programs or activities. The Human Resources Director has been designated to coordinate compliance with nondiscrimination requirements contained in Section 34.107 of the Department of Justice regulations. Information concerning the provisions of the Americans with Disabilities Act, and the rights provided thereafter, and Allen County's ADA Policy, are available from the ADA Coordinator. Requests for assistance or suggestions on how the County can better meet the needs of those persons with disabilities may be submitted to the ADA Coordinator at: Human Resources Department, 200 E. Berry, Suite 380, Fort Wayne, Indiana 46802, or by telephone at 260-449-7217, TDD 260-449-7881.